



MCPS RADON TESTING – EXECUTIVE SUMMARY

Site Name	Neelsville Middle School
Date of Test Report	4/6/2022
Round of Testing	Initial Follow-up Post Remediation 2 Year Testing 5 Year Testing HVAC Upgrade Window Replacement New Addition New Facility
# Rooms Tested	81
# Rooms \geq 4.0 pCi/L	0
Lowest Value	<0.3 pCi/L
Highest Value	2.5 pCi/L

Project Status:
Initial testing completed; no further action needed.



April 6, 2022

Brian T. Croyle, PG, CHMM
Environmental Specialist
Montgomery County Public Schools
Gaithersburg, MD 20879

Re: **Radon Testing Services**
KCI Job # 122108316

Location: Neelsville MS
11700 Neelsville Church Rd.
Germantown, MD 20876

Dear Mr. Croyle:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to Montgomery County Public Schools (MCPS) pursuant to completing a “short-term” 3 day radon test for the Neelsville MS, located at 11700 Neelsville Church Rd. Germantown, MD 20876 (subject site).

Scope of Services:

KCI conducted radon testing at the subject site to evaluate indoor radon levels relative to the USEPA's recommended action level of 4.0 picocuries per Liter (pCi/L) - the level at which EPA recommends that schools take action to reduce the level. KCI conducted the radon testing in accordance with American Association of Radon Scientists and Technologists (AARST) *Protocol for Conducting Measurements of Radon and Radon Decay Products in Schools and Large Buildings*. A National Radon Proficiency Program (NRPP) Radon Measurement Specialist (certification #111004 RT) supervised the testing. Additional information on radon management and the health effects of radon exposure is available from <https://www.montgomeryschoolsmd.org> or www.epa.gov/radon.

KCI visited the site on February 15, 2022 and deployed ninety four (94) activated charcoal (AC) radon test kits. KCI deployed radon test kits in all frequently-occupied ground contact rooms, and other areas, (if applicable) in accordance with AARST guidance.

A floor plan map of the building with the test locations is included as Attachment A of this report.

As a quality control measure, KCI also included duplicate samples, field blanks, lab transit blanks, and office blanks in accordance with AARST recommendations. In addition, KCI submitted test kits to Bowser-Morner, Inc. as spike samples. The spiked tests were exposed to a known radon concentration by Bowser-Morner prior to being returned to the laboratory for analysis.

KCI returned to the site on February 18, 2022 to retrieve the radon sampling test kits. KCI shipped all radon tests via overnight delivery to Airchek, Inc. for analysis by gamma-ray spectroscopy. Airchek, Inc.

is a NRSB certified analytical laboratory for radon analysis (certification # ARL1402) located at 1936 Butler Bridge Road, Mills River, North Carolina.

Evaluation of Testing Conditions:

These tests represent:

- Follow-up to post-mitigation biennial testing.

These tests were conducted to:

- Confirm the success of the mitigation system(s).

According to AARST, *Protocol for Conducting Measurements of Radon and Radon Decay Products in Schools and Large Buildings*, ideal testing conditions would be when the building is fully occupied and the heating system is active. For this test, the facility’s HVAC system was operating in heating mode; therefore, KCI concludes that this test was conducted during ideal testing conditions.

KCI recorded observations of the following conditions in each room during the time of deployment and collection of the radon test kits:

- Indoor temperature,
- HVAC Operation,
- Dehumidifier operation,
- Humidifier operation,
- Ceiling fan operation, and
- Open windows or doors.

KCI also compiled weather data for the testing period and conducted observations of relevant field conditions. During the test period, weather records indicate low temperatures were in the 20s and high temperatures ranged from the high 30s to the high 40s Fahrenheit. Maximum sustained winds ranged from 5-18 miles per hour. Average humidity was around 15% with 1.5 inches of precipitation (rain) was recorded during testing period.

Results:

The sampling locations and analytical results are listed on Table 1 (Attachment B). The quality control sample locations and analytical results are listed on Table 2 (Attachment B). Sampling locations and associated test kit identification numbers and relevant field observations are listed on Table 3 (Attachment B). The laboratory analytical results are included in Attachment C. Laboratory results and exposure data for the spike samples are also included in Attachment C.

The results of the radon test analysis indicated the following:

Radon Concentration	Room	Result
≥4.0 pCi/L	None	N/A
<4.0 pCi/L	See Attachment B	

Quality Control Samples	
Results of Blank Canisters:	The office blanks, and lab transit blanks had test results of less than the laboratory detection limit of 0.3 pCi/L.
Adequate Laboratory Precision?	Review of the duplicate sample analysis indicates that adequate laboratory measurement precision was achieved.
Spike Sample Analysis:	The Spike Sample analysis results indicate the laboratory is operating within statistical control limits.

Our professional services have been performed in accordance with customary principles and practices in the field of industrial hygiene and engineering. If you have any questions or comments regarding this report, please feel free to contact me at (410) 891-1769.

Sincerely,



Tyler P. McCleaf
Radon Measurement Provider
#111004 RT
KCI Technologies, Inc.

Attachments: A- Floor Plan with Test Locations
 B- Table 1-3, Radon Test Summary Spreadsheets
 C- Laboratory Analytical Results

ATTACHMENT A

Floor Plan With Test Locations

ATTACHMENT B

Radon Test Summary Spreadsheet

Table Notes:

AC- Activated Charcoal

ACI- Air Check, Inc.

D- Duplicate

FB- Field Blank

KCI- KCI Technologies, Inc.

OB- Office Blank

PM- Project Manager

OC- Quality Control

Table 1- Radon Testing Results		
Neelsville MS		
Test Period: 02/15/2022 - 02/18/2022		
Kit Number	Room / Area	Result
11123403	100	1.1
11122594	101	1.2
11123414	102	0.9
11123407	103	2.5
11123436	106	1.3
11123411	107	0.9
11123410	108	0.5
11123417	109	< 0.3
11123427	109	0.5
11123428	109	0.6
11123419	110	1.1
11123406	111	0.6
11123412	112	0.7
11122595	113	< 0.3
11122596	114	0.9
11123408	115	< 0.3
11123416	116	< 0.3
11123421	117	< 0.3
11123401	120	1.3
11123409	121	1.6
11123415	122	1.1
11123420	122	1.3
11122600	206	0.7
11122598	207	1.0
11115113	210	0.7
11115129	211	1.6
11115137	213	1.3
11115127	214	0.9
11115147	215	0.8
11115130	216	0.9
11115120	217	1.1
11115136	217	1.0
11115142	218	0.8
11115138	219	0.8
11115119	220	1.6
11115141	221	0.7
11115122	222	0.8
11115123	223	0.8
11115128	225	< 0.3
11115144	225	0.8
11115135	226	0.8
11115121	227	< 0.3

Table 1- Radon Testing Results		
Neelsville MS		
Test Period: 02/15/2022 - 02/18/2022		
Kit Number	Room / Area	Result
11115124	228	1.0
11115131	228	< 0.3
11115132	228	0.9
11115126	229	< 0.3
11115140	230	0.6
11115125	231	< 0.3
11115139	232	< 0.3
11115143	235	< 0.3
11115146	236	< 0.3
11115145	237	< 0.3
11115102	239	< 0.3
11115111	239	0.9
11115118	240	0.7
11115116	241	0.8
11115112	242	0.8
11115103	243	0.7
11115115	245	0.7
11115107	246	< 0.3
11115106	247	0.8
11115105	248	< 0.3
11115101	249	< 0.3
11115108	249	< 0.3
11115110	249	< 0.3
11115133	250	< 0.3
11115109	251	1.0
11115134	252	1.1
11123429	111A	< 0.3
11123404	111C	< 0.3
11122593	111D	< 0.3
11123402	111D	< 0.3
11123405	111D	0.5
11123430	111E	< 0.3
11115149	AG AUX GYM	1.1
11115148	AG AUX. GYM	1.3
11123424	ASP ASST PRINCIPAL	0.8
11123432	ASP ASST PRINCIPAL	0.8
11123413	CAFETERIA	1.0
11123418	CAFETERIA	0.9
11123426	FOOD SERVICE OFFICE	< 0.3
11123434	FOOD SERVICE OFFICE	< 0.3
11123423	GOF GENERAL OFFICE	0.9
11123422	GYM	1.0

Table 1- Radon Testing Results		
Neelsville MS		
Test Period: 02/15/2022 - 02/18/2022		
Kit Number	Room / Area	Result
11123435	GYM	1.1
11123425	KITCHEN OF5	< 0.3
11115104	MEDIA CENTER	0.8
11115114	MEDIA CENTER	< 0.3
11123439	OFFICE CONF ROOM	0.7
11123433	OFFICE WORK ROOM	0.9
11123431	PR PRINCIPAL OFFICE	0.9
11123437	SECURITY OFFICE	1.3
11122599	STAFF LOUNGE	0.8
11123438	STAGE	1.5

Table 2- Radon Testing Results			
Neelsville MS			
Test Period: 02/15/2022 - 02/18/2022			
Kit Number	QC Type	Room / Area	Result
11123434	D	Food Service Office	< 0.3
11123417	D	109	< 0.3
11123428	FB	109	0.6
11123415	D	122	1.1
11123402	D	111D	< 0.3
11122593	FB	111D	< 0.3
11115111	D	239	0.9
11115101	D	249	< 0.3
11115108	FB	249	< 0.3
11115136	D	217	1.0
11115124	D	228	1.0
11115131	FB	228	< 0.3
11115128	D	225	< 0.3
11131660	OB	OFFICE BLANK	< 0.3
11131661	TB	TRAVEL BLANK	< 0.3

ATTACHMENT C

Laboratory Analytical Results

Radon test result report for:

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11123403	100	2022-02-15 @ 12:00 pm	2022-02-18 @ 9:00 am	1.1 ± 0.3	2022-02-22
11122594	101	2022-02-15 @ 12:00 pm	2022-02-18 @ 9:00 am	1.2 ± 0.3	2022-02-22
11123414	102	2022-02-15 @ 10:00 am	2022-02-18 @ 9:00 am	0.9 ± 0.3	2022-02-22
11123407	103	2022-02-15 @ 12:00 pm	2022-02-18 @ 10:00 am	2.5 ± 0.4	2022-02-22
11123436	106	2022-02-15 @ 10:00 am	2022-02-18 @ 10:00 am	1.3 ± 0.3	2022-02-22
11123411	107	2022-02-15 @ 10:00 am	2022-02-18 @ 10:00 am	0.9 ± 0.3	2022-02-22
11123410	108	2022-02-15 @ 10:00 am	2022-02-18 @ 10:00 am	0.5 ± 0.3	2022-02-22
11123427	109	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	0.5 ± 0.3	2022-02-22
11123417	109	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	< 0.3	2022-02-22
11123428	109	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	0.6 ± 0.3	2022-02-22
11123419	110	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	1.1 ± 0.4	2022-02-22
11123406	111	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	0.6 ± 0.3	2022-02-22
11123429	111A	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	< 0.3	2022-02-22
11123404	111C	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	< 0.3	2022-02-22
11123405	111D	2022-02-15 @ 12:00 pm	2022-02-18 @ 10:00 am	0.5 ± 0.3	2022-02-22
11123402	111D	2022-02-15 @ 12:00 pm	2022-02-18 @ 10:00 am	< 0.3	2022-02-22
11122593	111D	2022-02-15 @ 12:00 pm	2022-02-18 @ 10:00 am	< 0.3	2022-02-22
11123430	111E	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	< 0.3	2022-02-22
11123412	112	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	0.7 ± 0.3	2022-02-22
11122595	113	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	< 0.3	2022-02-22
11122596	114	2022-02-15 @ 12:00 pm	2022-02-18 @ 10:00 am	0.9 ± 0.3	2022-02-22
11123408	115	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	< 0.3	2022-02-22
11123416	116	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	< 0.3	2022-02-22
11123421	117	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	< 0.3	2022-02-22
11123401	120	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	1.3 ± 0.3	2022-02-22
11123409	121	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	1.6 ± 0.4	2022-02-22
11123415	122	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	1.1 ± 0.3	2022-02-22
11123420	122	2022-02-15 @ 11:00 am	2022-02-18 @ 10:00 am	1.3 ± 0.4	2022-02-22
11122600	206	2022-02-15 @ 12:00 pm	2022-02-18 @ 11:00 am	0.7 ± 0.3	2022-02-22
11122598	207	2022-02-15 @ 12:00 pm	2022-02-18 @ 11:00 am	1.0 ± 0.3	2022-02-22
11115113	210	2022-02-15 @ 12:00 pm	2022-02-18 @ 11:00 am	0.7 ± 0.3	2022-02-22
11115129	211	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	1.6 ± 0.4	2022-02-22
11115137	213	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	1.3 ± 0.4	2022-02-22
11115127	214	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	0.9 ± 0.3	2022-02-22
11115147	215	2022-02-15 @ 2:00 pm	2022-02-18 @ 11:00 am	0.8 ± 0.3	2022-02-22
11115130	216	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	0.9 ± 0.3	2022-02-22
11115136	217	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	1.0 ± 0.3	2022-02-22

Radon test result report for:

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11115120	217	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	1.1 ± 0.4	2022-02-22
11115142	218	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	0.8 ± 0.3	2022-02-22
11115138	219	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	0.8 ± 0.3	2022-02-22
11115119	220	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	1.6 ± 0.4	2022-02-22
11115141	221	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	0.7 ± 0.3	2022-02-22
11115122	222	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	0.8 ± 0.3	2022-02-22
11115123	223	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	0.8 ± 0.3	2022-02-22
11115144	225	2022-02-15 @ 2:00 pm	2022-02-18 @ 11:00 am	0.8 ± 0.3	2022-02-22
11115128	225	2022-02-15 @ 2:00 pm	2022-02-18 @ 11:00 am	< 0.3	2022-02-22
11115135	226	2022-02-15 @ 2:00 pm	2022-02-18 @ 12:00 pm	0.8 ± 0.3	2022-02-22
11115121	227	2022-02-15 @ 2:00 pm	2022-02-18 @ 12:00 pm	< 0.3	2022-02-22
11115131	228	2022-02-15 @ 2:00 pm	2022-02-18 @ 12:00 pm	< 0.3	2022-02-22
11115132	228	2022-02-15 @ 2:00 pm	2022-02-18 @ 12:00 pm	0.9 ± 0.3	2022-02-22
11115124	228	2022-02-15 @ 2:00 pm	2022-02-18 @ 12:00 pm	1.0 ± 0.3	2022-02-22
11115126	229	2022-02-15 @ 2:00 pm	2022-02-18 @ 12:00 pm	< 0.3	2022-02-22
11115140	230	2022-02-15 @ 1:00 pm	2022-02-18 @ 12:00 pm	0.6 ± 0.3	2022-02-22
11115125	231	2022-02-15 @ 2:00 pm	2022-02-18 @ 12:00 pm	< 0.3	2022-02-22
11115139	232	2022-02-15 @ 2:00 pm	2022-02-18 @ 12:00 pm	< 0.3	2022-02-22
11115143	235	2022-02-15 @ 2:00 pm	2022-02-18 @ 11:00 am	< 0.3	2022-02-22
11115146	236	2022-02-15 @ 2:00 pm	2022-02-18 @ 12:00 pm	< 0.3	2022-02-22
11115145	237	2022-02-15 @ 2:00 pm	2022-02-18 @ 11:00 am	< 0.3	2022-02-22
11115111	239	2022-02-15 @ 12:00 pm	2022-02-18 @ 11:00 am	0.9 ± 0.3	2022-02-22
11115102	239	2022-02-15 @ 12:00 pm	2022-02-18 @ 11:00 am	< 0.3	2022-02-22
11115118	240	2022-02-15 @ 12:00 pm	2022-02-18 @ 11:00 am	0.7 ± 0.3	2022-02-22
11115116	241	2022-02-15 @ 12:00 pm	2022-02-18 @ 12:00 pm	0.8 ± 0.3	2022-02-22
11115112	242	2022-02-15 @ 12:00 pm	2022-02-18 @ 12:00 pm	0.8 ± 0.3	2022-02-22
11115103	243	2022-02-15 @ 12:00 pm	2022-02-18 @ 12:00 pm	0.7 ± 0.3	2022-02-22
11115115	245	2022-02-15 @ 1:00 pm	2022-02-18 @ 12:00 pm	0.7 ± 0.3	2022-02-22
11115107	246	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	< 0.3	2022-02-22
11115106	247	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	0.8 ± 0.3	2022-02-22
11115105	248	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	< 0.3	2022-02-22
11115108	249	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	< 0.3	2022-02-22
11115101	249	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	< 0.3	2022-02-22
11115110	249	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	< 0.3	2022-02-22
11115133	250	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	< 0.3	2022-02-22
11115109	251	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	1.0 ± 0.3	2022-02-22
11115134	252	2022-02-15 @ 1:00 pm	2022-02-18 @ 11:00 am	1.1 ± 0.3	2022-02-22

Radon test result report for:

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11115149	AG AUX GYM	2022-02-15 @ 2:00 pm	2022-02-18 @ 9:00 am	1.1 ± 0.3	2022-02-22
11115148	AG AUX. GYM	2022-02-15 @ 2:00 pm	2022-02-18 @ 9:00 am	1.3 ± 0.3	2022-02-22
11123424	ASP ASST PRINCIPAL	2022-02-15 @ 9:00 am	2022-02-18 @ 9:00 am	0.8 ± 0.3	2022-02-22
11123432	ASP ASST PRINCIPAL	2022-02-15 @ 10:00 am	2022-02-18 @ 12:00 pm	0.8 ± 0.3	2022-02-22
11123413	CAFETERIA	2022-02-15 @ 10:00 am	2022-02-18 @ 10:00 am	1.0 ± 0.3	2022-02-22
11123418	CAFETERIA	2022-02-15 @ 10:00 am	2022-02-18 @ 10:00 am	0.9 ± 0.3	2022-02-22
11123434	FOOD SERVICE OFFICE	2022-02-15 @ 10:00 am	2022-02-18 @ 10:00 am	< 0.3	2022-02-22
11123426	FOOD SERVICE OFFICE	2022-02-15 @ 10:00 am	2022-02-18 @ 10:00 am	< 0.3	2022-02-22
11123423	GOF GENERAL OFFICE	2022-02-15 @ 9:00 am	2022-02-18 @ 9:00 am	0.9 ± 0.3	2022-02-22
11123435	GYM	2022-02-15 @ 10:00 am	2022-02-18 @ 9:00 am	1.1 ± 0.3	2022-02-22
11123422	GYM	2022-02-15 @ 10:00 am	2022-02-18 @ 9:00 am	1.0 ± 0.3	2022-02-22
11123425	KITCHEN OF5	2022-02-15 @ 10:00 am	2022-02-18 @ 10:00 am	< 0.3	2022-02-22
11115114	MEDIA CENTER	2022-02-15 @ 12:00 pm	2022-02-18 @ 11:00 am	< 0.3	2022-02-22
11115104	MEDIA CENTER	2022-02-15 @ 12:00 pm	2022-02-18 @ 11:00 am	0.8 ± 0.3	2022-02-22
11123439	OFFICE CONF ROOM	2022-02-15 @ 10:00 am	2022-02-18 @ 9:00 am	0.7 ± 0.3	2022-02-22
11123433	OFFICE WORK ROOM	2022-02-15 @ 9:00 am	2022-02-18 @ 9:00 am	0.9 ± 0.3	2022-02-22
11123431	PR PRINCIPAL OFFICE	2022-02-15 @ 10:00 am	2022-02-18 @ 9:00 am	0.9 ± 0.3	2022-02-22
11123437	SECURITY OFFICE	2022-02-15 @ 10:00 am	2022-02-18 @ 10:00 am	1.3 ± 0.3	2022-02-22
11122599	STAFF LOUNGE	2022-02-15 @ 12:00 pm	2022-02-18 @ 11:00 am	0.8 ± 0.3	2022-02-22
11123438	STAGE	2022-02-15 @ 11:00 am	2022-02-18 @ 9:00 am	1.5 ± 0.3	2022-02-22

EXPOSURE IN BOWSER-MORNER RADON CHAMBER

CLIENT KCI Technologies, Inc. Job Number 204186

NOMINAL Conditions: Radon Conc 25.8 pCi/L Rel. Hum 50.1 % Temp. 70.9 F

Date Start: 2/18/22 Date Stop: 2/21/22 Date Start: _____ Date Stop: _____

Time Start: 0911 Time Stop: 0911 Time Start: _____ Time Stop: _____

Device No.'s: (3) Char Bags -
11113484, 1112998, 20107126 Device No.'s: _____

23 Right

Date Start: _____ Date Stop: _____ Date Start: _____ Date Stop: _____

Time Start: _____ Time Stop: _____ Time Start: _____ Time Stop: _____

Device No.'s: _____ Device No.'s: _____

Date Start: _____ Date Stop: _____ Date Start: _____ Date Stop: _____

Time Start: _____ Time Stop: _____ Time Start: _____ Time Stop: _____

Device No.'s: _____ Device No.'s: _____

**Note: All times are in 24-hour (military) notation, Eastern Standard Time (EST)
Background = 7 µR/h Elevation = 820 ft**

MCPS - Spike Sample Lab Results. Measured values are satisfactory, i.e., within $\pm 25\%$ of the chamber's reference value (25.7 pCi/L).

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
11113484	2022-02-18	9:00 am	2022-02-21	9:00 am	71	OFFICE	MAIN	SK1		1	27.9
11122998	2022-02-18	9:00 am	2022-02-21	9:00 am	71	OFFICE	MAIN	SK2		1	26.0
20107126	2022-02-18	9:00 am	2022-02-21	9:00 am	71	OFFICE	MAIN	SK3		1	27.6



Radon Test Kit Chain of Custody

Project Name: MCPS Radon – February 2022 Schools

Name of Schools:

1. Damascus HS
2. Germantown ES
3. Great Seneca Creek ES
4. Lake Seneca ES
5. S. Christa McAuliffe ES
6. Northwest HS
7. Waters Landing ES
8. Seneca Valley HS
9. Cedar Grove ES
10. Capt. James E. Daly ES
11. Neelsville MS
12. Dr. Sally K. Ride ES

	Date	Initials
Radon Test Kits Deployed	02/15/2022	DM
Radon Test Kits Collected	02/18/2022	DM
Radon Test Kits Shipped to Lab*	02/18/2022	DM
Radon Test Kits Received by Lab*	02/21/2022	DM

*All samples sent to Air Check, Inc., 1936 Butler Bridge Rd, Mills River, NC 28759