



**MCPS RADON TESTING – EXECUTIVE SUMMARY**

Site Name	Rosemary Hills Elementary School
Date of Test Report	4/29/2022
Round of Testing	Initial Follow-up Post Remediation 2 Year Testing 5 Year Testing HVAC Upgrade Window Replacement New Addition New Facility
# Rooms Tested	77
# Rooms $\geq$ 4.0 pCi/L	0
Lowest Value	<0.3 pCi/L
Highest Value	0.8 pCi/L

Project Status:  
Initial testing completed; no further action needed



April 29, 2022

Brian T. Croyle, PG, CHMM  
Environmental Specialist  
Montgomery County Public Schools  
Gaithersburg, MD 20879

Re: **Radon Testing Services**  
KCI Job # 122108316

Location: Rosemary Hills Elementary School  
2111 Porter Rd.  
Silver Spring, MD 20910

Dear Mr. Croyle:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to Montgomery County Public Schools (MCPS) pursuant to completing a “short-term” 3 day radon test for the Rosemary Hills Elementary School, located at 2111 Porter Rd. Silver Spring, MD 20910 (subject site).

**Scope of Services:**

KCI conducted radon testing at the subject site to evaluate indoor radon levels relative to the USEPA's recommended action level of 4.0 picocuries per Liter (pCi/L) - the level at which EPA recommends that schools take action to reduce the level. KCI conducted the radon testing in accordance with American Association of Radon Scientists and Technologists (AARST) *Protocol for Conducting Measurements of Radon and Radon Decay Products in Schools and Large Buildings*. A National Radon Proficiency Program (NRPP) Radon Measurement Specialist (certification #111004 RT) supervised the testing. Additional information on radon management and the health effects of radon exposure is available from <https://www.montgomeryschoolsmd.org> or [www.epa.gov/radon](http://www.epa.gov/radon).

KCI visited the site on March 8, 2022 and deployed eighty-five (85) activated charcoal (AC) radon test kits. KCI deployed radon test kits in all frequently-occupied ground contact rooms, and other areas, (if applicable) in accordance with AARST guidance.

A floor plan map of the building with the test locations is included as Attachment A of this report.

As a quality control measure, KCI also included duplicate samples, field blanks, lab transit blanks, and office blanks in accordance with AARST recommendations. In addition, KCI submitted test kits to Bowser-Morner, Inc. as spike samples. The spiked tests were exposed to a known radon concentration by Bowser-Morner prior to being returned to the laboratory for analysis.

KCI returned to the site on March 11, 2022 to retrieve the radon sampling test kits. KCI shipped all radon tests via overnight delivery to Airchek, Inc. for analysis by gamma-ray spectroscopy. Airchek, Inc. is a

NRSB certified analytical laboratory for radon analysis (certification # ARL1402) located at 1936 Butler Bridge Road, Mills River, North Carolina.

**Evaluation of Testing Conditions:**

These tests represent:

- Follow-up to initial testing.
- Initial testing

These tests were conducted to:

- Evaluate radon concentration levels at the facility
- Evaluate radon concentration levels due to HVAC upgrades/replacement.

According to AARST, *Protocol for Conducting Measurements of Radon and Radon Decay Products in Schools and Large Buildings*, ideal testing conditions would be when the building is fully occupied and the heating system is active. For this test, the facility's HVAC system was operating in heating mode; therefore, KCI concludes that this test was conducted during ideal testing conditions.

KCI recorded observations of the following conditions in each room during the time of deployment and collection of the radon test kits:

- Indoor temperature,
- HVAC Operation,
- Dehumidifier operation,
- Humidifier operation,
- Ceiling fan operation, and
- Open windows or doors.

KCI also compiled weather data for the testing period and conducted observations of relevant field conditions. During the test period, weather records indicate low temperatures were in the mid 20s and high temperatures ranged from the high 70s to the low 50s Fahrenheit. Maximum sustained winds ranged from 0-32 miles per hour. Average humidity was around 65% with 1.09 inches of precipitation (rain) was recorded during testing period.

**Results:**

The sampling locations and analytical results are listed on Table 1 (Attachment B). The quality control sample locations and analytical results are listed on Table 2 (Attachment B). Sampling locations and associated test kit identification numbers and relevant field observations are listed on Table 3 (Attachment B). The laboratory analytical results are included in Attachment C. Laboratory results and exposure data for the spike samples are also included in Attachment C.

The results of the radon test analysis indicated the following:

Radon Concentration	Room	Result
≥4.0 pCi/L	None	N/A
<4.0 pCi/L	See Attachment B	

Quality Control Samples	
Results of Blank Canisters:	The office blanks, and lab transit blanks had test results of less than the laboratory detection limit of 0.3 pCi/L.
Adequate Laboratory Precision?	Review of the duplicate sample analysis indicates that adequate laboratory measurement precision was achieved.
Spike Sample Analysis:	The Spike Sample analysis results indicate the laboratory is operating within statistical control limits.

Our professional services have been performed in accordance with customary principles and practices in the field of industrial hygiene and engineering. If you have any questions or comments regarding this report, please feel free to contact me at (410) 891-1769.

Sincerely,



Tyler P. McCleaf  
Radon Measurement Provider  
#111004 RT  
KCI Technologies, Inc.

Attachments:     A- Floor Plan with Test Locations  
                      B- Table 1-3, Radon Test Summary Spreadsheets  
                      C- Laboratory Analytical Results

# ATTACHMENT A

## Floor Plan With Test Locations

# ATTACHMENT B

## Radon Test Summary Spreadsheet

**Table Notes:**

AC- Activated Charcoal

ACI- Air Check, Inc.

D- Duplicate

FB- Field Blank

KCI- KCI Technologies, Inc.

OB- Office Blank

PM- Project Manager

OC- Quality Control

Table 1- Radon Testing Results		
Rosemary Hills ES		
Test Period: 03/08/2022 - 03/11/2022		
Kit Number	Room / Area	Result
11132682	100	< 0.3
11132625	101	< 0.3
11132641	101	< 0.3
11132694	101	< 0.3
11132681	102	< 0.3
11132663	104	< 0.3
11132665	105	< 0.3
11132690	106	< 0.3
11132626	111	< 0.3
11132667	111	< 0.3
11132677	115	< 0.3
11132695	115	0.6
11132662	116	< 0.3
11132644	117	0.8
11132659	117	< 0.3
11132660	117	< 0.3
11132661	118	< 0.3
11132645	121	< 0.3
11132670	150	< 0.3
11132650	151	< 0.3
11132688	151	< 0.3
11132668	156	< 0.3
11132648	160	< 0.3
11132678	161	< 0.3
11132647	165	< 0.3
11133859	203	< 0.3
11133879	204	< 0.3
11133878	205	< 0.3
11133881	205	< 0.3
11132612	206	< 0.3
11132611	207	< 0.3
11132604	208	< 0.3
11132655	210	< 0.3
11132631	212	< 0.3
11132602	213	< 0.3
11133855	214	< 0.3
11132638	215	< 0.3
11132603	216	< 0.3
11132607	216	< 0.3
11132608	216	< 0.3
11133884	252	< 0.3
11132658	300	< 0.3



Table 1- Radon Testing Results		
Rosemary Hills ES		
Test Period: 03/08/2022 - 03/11/2022		
Kit Number	Room / Area	Result
11132687	301	< 0.3
11132664	302	< 0.3
11132653	304	< 0.3
11132679	306	< 0.3
11132651	309	< 0.3
11132629	310	< 0.3
11132633	312	< 0.3
11132674	312	< 0.3
11132630	314	< 0.3
11132656	315	< 0.3
11132680	316	< 0.3
11132601	317	0.5
11132673	318	< 0.3
11132632	319	< 0.3
11132635	319	< 0.3
11132652	400	< 0.3
11132666	401	< 0.3
11132637	402	< 0.3
11132636	403	< 0.3
11132643	119A	< 0.3
11132657	119D	< 0.3
11132693	119E	< 0.3
11132646	121A	< 0.3
11132642	121B	0.7
11132669	150B	< 0.3
11132676	150C	< 0.3
11132649	153C	< 0.3
11132675	153D	< 0.3
11133880	205 OFFICE	< 0.3
11132627	307A	< 0.3
11132671	307A	< 0.3
11132672	307A	< 0.3
11132628	312 OFFICE	< 0.3
11132639	ASSISTANT PRINCIPAL	0.7
11132606	GYM	< 0.3
11132634	GYM	< 0.3
11132605	GYM OFFICE	< 0.3
11132686	KITCHEN	< 0.3
11132654	MEDIA OFFICE	0.5
11132640	NURSE	< 0.3
11132610	OLD MAIN OFFICE	< 0.3
11133856	PRINCIPAL	< 0.3

Table 1- Radon Testing Results		
Rosemary Hills ES		
Test Period: 03/08/2022 - 03/11/2022		
Kit Number	Room / Area	Result
11133882	WORKROOM	< 0.3

Table 2- Radon Testing Results			
Rosemary Hills ES			
Test Period: 03/08/2022 - 03/11/2022			
Kit Number	QC Type	Room / Area	Result
11132625	D	101	< 0.3
11132694	FB	101	< 0.3
11132659	D	117	< 0.3
11132627	D	307a	< 0.3
11132672	FB	307a	< 0.3
11132632	D	319	< 0.3
11132608	D	216	< 0.3
11133881	D	205	< 0.3
11131663	OB	OFFICE BLANK	< 0.3
11131669	TB	TRAVEL BLANK	< 0.3

Summary of Missed Locations		
Rosemary Hill ES		
Test Period: 03/08/22 - 03/11/22		
Kit Number	Room/Area	Result
	NA	

Summary of Missing, Compromised and >= 4 piC/L Tests		
Rosemary Hills ES		
Test Period: 03/08/22 - 03/11/22		
Kit Number	Room/Area	Result
	NA	

Table Note:  
 \* Missing or Compromised Sample

# ATTACHMENT C

## Laboratory Analytical Results

Radon test result report for:  
**ROSEMARY HILLS ES**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11132682	100	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132625	101	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132641	101	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132694	101	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132681	102	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132663	104	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132665	105	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132690	106	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132626	111	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132667	111	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132695	115	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	0.6 ± 0.3	2022-03-14
11132677	115	2022-03-08 @ 11:00 am	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132662	116	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132660	117	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132659	117	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132644	117	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	0.8 ± 0.3	2022-03-14
11132661	118	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132643	119A	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132657	119D	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132693	119E	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132645	121	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132646	121A	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132642	121B	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	0.7 ± 0.3	2022-03-14
11132670	150	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132669	150B	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132676	150C	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132650	151	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132688	151	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132649	153C	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132675	153D	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132668	156	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132648	160	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132678	161	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132647	165	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11133859	203	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11133879	204	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11133878	205	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14

Radon test result report for:  
**ROSEMARY HILLS ES**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11133881	205	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11133880	205 OFFICE	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132612	206	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132611	207	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132604	208	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132655	210	2022-03-08 @ 11:00 am	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132631	212	2022-03-08 @ 11:00 am	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132602	213	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11133855	214	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132638	215	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132603	216	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132607	216	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132608	216	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11133884	252	2022-03-08 @ 12:00 pm	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132658	300	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132687	301	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132664	302	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132653	304	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132679	306	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132672	307A	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132627	307A	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132671	307A	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132651	309	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132629	310	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132633	312	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132674	312	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132628	312 OFFICE	2022-03-08 @ 11:00 am	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132630	314	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132656	315	2022-03-08 @ 11:00 am	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132680	316	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132601	317	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	0.5 ± 0.3	2022-03-14
11132673	318	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132635	319	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132632	319	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132652	400	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132666	401	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132637	402	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14

March 15, 2022

**\*\* LABORATORY ANALYSIS REPORT \*\***

Radon test result report for:  
**ROSEMARY HILLS ES**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11132636	403	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132639	ASSISTANT PRINCIPAL	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	0.7 ± 0.3	2022-03-14
11132634	GYM	2022-03-08 @ 11:00 am	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132606	GYM	2022-03-08 @ 11:00 am	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132605	GYM OFFICE	2022-03-08 @ 11:00 am	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132686	KITCHEN	2022-03-08 @ 10:00 am	2022-03-11 @ 9:00 am	< 0.3	2022-03-14
11132654	MEDIA OFFICE	2022-03-08 @ 11:00 am	2022-03-11 @ 9:00 am	0.5 ± 0.3	2022-03-14
11132640	NURSE	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11132610	OLD MAIN OFFICE	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11133856	PRINCIPAL	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14
11133882	WORKROOM	2022-03-08 @ 12:00 pm	2022-03-11 @ 10:00 am	< 0.3	2022-03-14

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498



# EXPOSURE IN BOWSER-MORNER RADON CHAMBER

CLIENT KCI Technologies, Inc. Job Number 204620

NOMINAL Conditions: Radon Conc 27.0 pCi/L Rel. Hum 50.1 % Temp. 70.0 F

Date Start: 3/18/22 Date Stop: 3/21/22 Date Start: \_\_\_\_\_ Date Stop: \_\_\_\_\_

Time Start: 0705 Time Stop: 0705 Time Start: \_\_\_\_\_ Time Stop: \_\_\_\_\_

Device No.'s: (5) Char Bags - Device No.'s: \_\_\_\_\_

11139367, 11139368, 11139371, \_\_\_\_\_

11139710, 11139717 \_\_\_\_\_

E3 light

Date Start: \_\_\_\_\_ Date Stop: \_\_\_\_\_ Date Start: \_\_\_\_\_ Date Stop: \_\_\_\_\_

Time Start: \_\_\_\_\_ Time Stop: \_\_\_\_\_ Time Start: \_\_\_\_\_ Time Stop: \_\_\_\_\_

Device No.'s: \_\_\_\_\_ Device No.'s: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Date Start: \_\_\_\_\_ Date Stop: \_\_\_\_\_ Date Start: \_\_\_\_\_ Date Stop: \_\_\_\_\_

Time Start: \_\_\_\_\_ Time Stop: \_\_\_\_\_ Time Start: \_\_\_\_\_ Time Stop: \_\_\_\_\_

Device No.'s: \_\_\_\_\_ Device No.'s: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Note: All times are in 24-hour (military) notation, Eastern Standard Time (EST)  
Background = 7  $\mu$ R/h Elevation = 820 ft

---

March 30, 2022

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

MCPS - Spike Sample Lab Results. Measured values are satisfactory, i.e., within  $\pm 25\%$  of the chamber's reference value (25.7 pCi/L).

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
11139367	SK1	2022-03-18 @ 7:00 am	2022-03-21 @ 7:00 am	25.9 $\pm$ 2.1	2022-03-30
11139368	SK2	2022-03-18 @ 7:00 am	2022-03-21 @ 7:00 am	23.9 $\pm$ 2.0	2022-03-30
11139371	SK3	2022-03-18 @ 7:00 am	2022-03-21 @ 7:00 am	25.7 $\pm$ 2.1	2022-03-30
11139710	SK4	2022-03-18 @ 7:00 am	2022-03-21 @ 7:00 am	26.4 $\pm$ 2.1	2022-03-30
11139717	SK5	2022-03-18 @ 7:00 am	2022-03-21 @ 7:00 am	24.6 $\pm$ 2.0	2022-03-30

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498



## Radon Test Kit Chain of Custody

Project Name: MCPS Radon – March 2022 Schools

Name of Schools:

1. Fairland Center
2. Cloverly ES
3. Drew, Dr. Charles ES
4. Weller Road ES
5. Wheaton HS
6. East Silver Spring ES
7. Rosemary Hills ES

---

	Date	Initials
Radon Test Kits Deployed	03/08/2022	BMM
Radon Test Kits Collected	03/11/2022	BMM
Radon Test Kits Shipped to Lab*	03/11/2022	BMM
Radon Test Kits Received by Lab*	03/13/2022	BMM

\*All samples sent to Air Check, Inc., 1936 Butler Bridge Rd, Mills River, NC 28759