

Montgomery County Public Schools Lead in Drinking Water Testing Report

**Burtonsville Elementary School
15516 Old Columbia Pike
Burtonsville, MD 20866**

Report Date: April 29th, 2024

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the State Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by Inspection Experts Inc. is presented in the table below.

Sampling Date	2/23/2024
# of Outlets Tested	44
# of Outlets \geq 5 ppb	4

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be shut-down within 24 hours, a follow-up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass outlets, food, cosmetics, exposure in the work place and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s) A – Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for Burtonsville ES

Outlet Barcode	Outlet Location	Outlet Type	Initial Results (ppb)	Pass/Fail	Status
M45738	In classroom 57	Drinking Water fountain - Bubblers Style	1.1	Pass	Testing Complete
M45744	In classroom 12	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
M45746	In classroom 11	Drinking Water fountain - Bubblers Style	2.7	Pass	Testing Complete
M45750	In classroom 9	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
M45755	In classroom 6	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
M45772	In kitchen by cafeteria	Faucet, Cold	<1.0	Pass	Testing Complete
M45773	In kitchen by cafeteria	Faucet, Cold	<1.0	Pass	Testing Complete
M45774	In kitchen by cafeteria	Faucet, Cold	<1.0	Pass	Testing Complete
M45786	In health room	Faucet, Cold	<1.0	Pass	Testing Complete
M45736	In classroom 55	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
LW01803	In hallway in front of gymnasium	Drinking Water Fountain - Cooler/Chiller Style	<1.0	Pass	Testing Complete

Outlet Barcode	Outlet Location	Outlet Type	Initial Results (ppb)	Pass/Fail	Status
LW01804	In classroom 24	Drinking Water fountain - Bubblers Style	2.0	Pass	Testing Complete
LW01807	In classroom 20	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
LW01810	In hallway adjacent from classroom 19	Drinking Water Fountain - Cooler/Chiller Style	<1.0	Pass	Testing Complete
LW01812	In classroom 17	Drinking Water fountain - Bubblers Style	1.2	Pass	Testing Complete
LW01815	In classroom 14	Drinking Water fountain - Bubblers Style	1.3	Pass	Testing Complete
LW01817	In classroom 13	Drinking Water fountain - Bubblers Style	2.6	Pass	Testing Complete
LW01842	In hallway across room 28	Drinking Water Fountain - Cooler/Chiller Style	<1.0	Pass	Testing Complete
LW13122	In classroom 30	Drinking Water fountain - Bubblers Style	2.4	Pass	Testing Complete
LW13119	In break room 7	Faucet, Cold	3.3	Pass	Testing Complete
LW06936	In classroom 4	Drinking Water fountain - Bubblers Style	1.2	Pass	Testing Complete
LW06942	In classroom 1	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
M40119	In classroom 21	Drinking Water fountain - Bubblers Style	3.9	Pass	Testing Complete

Outlet Barcode	Outlet Location	Outlet Type	Initial Results (ppb)	Pass/Fail	Status
M45681	In classroom 42	Drinking Water fountain - Bubblers Style	60.6	Fail	Remediation Action Plan
M45685	In classroom 28	Drinking Water fountain - Bubblers Style	1.2	Pass	Testing Complete
M45692	In classroom 33	Drinking Water fountain - Bubblers Style	12.7	Fail	Remediation Action Plan
M45703	In classroom 27	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
M45705	In classroom 26	Drinking Water fountain - Bubblers Style	1.8	Pass	Testing Complete
M45709	In classroom 25	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
M45713	In classroom 22	Drinking Water fountain - Bubblers Style	1.0	Pass	Testing Complete
M45717	In classroom 19	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
M45724	In classroom 18	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
M45733	In classroom 58	Drinking Water fountain - Bubblers Style	11.2	Fail	Remediation Action Plan
LW13118	Hallway across All purpose room	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
LW13117	Hallway across All purpose room	Bottle Refill Dispenser/Water Refill Station	<1.0	Pass	Testing Complete

Outlet Barcode	Outlet Location	Outlet Type	Initial Results (ppb)	Pass/Fail	Status
LW13123	In classroom 3	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
LW06959	By the main office	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
LW13120	Classroom 30	Drinking Water fountain - Bubblers Style	12.5	Fail	Remediation Action Plan
LW13116	Classroom 2	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
M45753	Classroom 8	Drinking Water fountain - Bubblers Style	1.3	Pass	Testing Complete
M45748	Classroom 10	Drinking Water fountain - Bubblers Style	2.6	Pass	Testing Complete
LW01805	Classroom 23	Drinking Water fountain - Bubblers Style	<1.0	Pass	Testing Complete
LW13115	In hallway across from classroom 58	Drinking Water Fountain - Cooler/Chiller Style	<1.0	Pass	Testing Complete
M45723	Classroom 18	Drinking Water Fountain - Cooler/Chiller Style	1.1	Pass	Testing Complete

Montgomery County Public Schools Lead in Drinking Water Testing Report

**Burtonsville Elementary School
15516 Old Columbia Pike
Burtonsville, MD 20866**

Report Date: February 18th, 2022

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the Montgomery County Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by SaLUT are presented in the table below.

Sampling Date	11/02/2021
# of Outlets Tested	67
# of Outlets \geq 5 ppb	7

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be immediately shut-down, a follow-up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, cosmetics, exposure in the work place and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s) A – Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for Burtonsville ES

Fixture Barcode	Fixture Location	Fixture Type	Initial Results (ppb)	Pass/Fail	Follow up Results (ppb)	Status
LW01803	In hallway In front of gymnasium	Drinking Fountain	<1	Pass	N/A	Testing Complete
LW01804	In classroom 24	Classroom Combination Drinking Fountain	2.3	Pass	N/A	Testing Complete
LW01806	In classroom 20	Classroom Combination Sink	1.3	Pass	N/A	Testing Complete
LW01807	In classroom 20	Classroom Combination Drinking Fountain	2.5	Pass	N/A	Testing Complete
LW01810	In hallway adjacent from classroom 19	Drinking Fountain	<1	Pass	N/A	Testing Complete
LW01811	In classroom 17	Classroom Combination Sink	2.3	Pass	N/A	Testing Complete
LW01812	In classroom 17	Classroom Combination Drinking Fountain	2.9	Pass	N/A	Testing Complete
LW01814	In classroom 14	Classroom Combination Sink	1.5	Pass	N/A	Testing Complete
LW01815	In classroom 14	Classroom Combination Drinking Fountain	1.3	Pass	N/A	Testing Complete
LW01816	In classroom 13	Classroom Combination Sink	<1	Pass	N/A	Testing Complete
LW01817	In classroom 13	Classroom Combination Drinking Fountain	2.4	Pass	N/A	Testing Complete
LW01842	In hallway across room 28	Drinking Fountain	<1	Pass	N/A	Testing Complete
LW01843	In classroom 30	Classroom Combination Sink	<1	Pass	N/A	Testing Complete
LW01844	In classroom 30	Classroom Combination Drinking Fountain	5.4	Fail	5.8	Testing Complete
LW06934	In break room 7	Teachers Lounge Sink	<1	Pass	N/A	Testing Complete
LW06935	In classroom 4	Classroom Combination Sink	1.1	Pass	N/A	Testing Complete
LW06936	In classroom 4	Classroom Combination Drinking Fountain	4.5	Pass	N/A	Testing Complete
LW06937	In classroom 3	Classroom Combination Sink	1.4	Pass	N/A	Testing Complete
LW06939	In classroom 2	Classroom Combination Sink	<1	Pass	N/A	Testing Complete
LW06941	In classroom 1	Classroom Combination Sink	<1	Pass	N/A	Testing Complete
LW06942	In classroom 1	Classroom Combination Drinking Fountain	1.2	Pass	N/A	Testing Complete
LW11032	In hallway adjacent to all purpose room	Bottle Filler	<1	Pass	N/A	Testing Complete
M40119	In classroom 21	Classroom Combination Drinking Fountain	2.1	Pass	N/A	Testing Complete
M40122	In classroom 21	Classroom Combination Sink	<1	Pass	N/A	Testing Complete
M45680	In classroom 42	Classroom Combination Sink	3.2	Pass	N/A	Testing Complete
M45681	In classroom 42	Classroom Combination Drinking Fountain	2.5	Pass	N/A	Testing Complete
M45684	In classroom 28	Classroom Combination Sink	1.4	Pass	N/A	Testing Complete
M45685	In classroom 28	Classroom Combination Drinking Fountain	4.3	Pass	N/A	Testing Complete
M45691	In classroom 33	Classroom Combination Sink	3.2	Pass	N/A	Testing Complete
M45692	In classroom 33	Classroom Combination Drinking Fountain	7.7	Fail	113	Testing Complete

M45693	In classroom 35	Classroom Combination Sink	1.7	Pass	N/A	Testing Complete
M45694	In classroom 35	Classroom Combination Drinking Fountain	3.4	Pass	N/A	Testing Complete
M45702	In classroom 27	Classroom Combination Sink	1.3	Pass	N/A	Testing Complete
M45703	In classroom 27	Classroom Combination Drinking Fountain	1.1	Pass	N/A	Testing Complete
M45704	In classroom 26	Classroom Combination Sink	1.8	Pass	N/A	Testing Complete
M45705	In classroom 26	Classroom Combination Drinking Fountain	8.0	Fail	189	Testing Complete
M45706	In classroom 24	Classroom Combination Sink	1.4	Pass	N/A	Testing Complete
M45708	In classroom 25	Classroom Combination Sink	1.7	Pass	N/A	Testing Complete
M45709	In classroom 25	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing Complete
M45710	In classroom 23	Classroom Combination Sink	2.6	Pass	N/A	Testing Complete
M45712	In classroom 22	Classroom Combination Sink	1.2	Pass	N/A	Testing Complete
M45713	In classroom 22	Classroom Combination Drinking Fountain	3.4	Pass	N/A	Testing Complete
M45716	In classroom 19	Classroom Combination Sink	3.2	Pass	N/A	Testing Complete
M45717	In classroom 19	Classroom Combination Drinking Fountain	1.4	Pass	N/A	Testing Complete
M45723	In classroom 18	Classroom Combination Sink	<1	Pass	N/A	Testing Complete
M45724	In classroom 18	Classroom Combination Drinking Fountain	2.3	Pass	N/A	Testing Complete
M45732	In classroom 58	Classroom Combination Sink	2.0	Pass	N/A	Testing Complete
M45733	In classroom 58	Classroom Combination Drinking Fountain	5.4	Fail	211	Testing Complete
M45735	In classroom 55	Classroom Combination Sink	1.8	Pass	N/A	Testing Complete
M45736	In classroom 55	Classroom Combination Drinking Fountain	1.3	Pass	N/A	Testing Complete
M45737	In classroom 57	Classroom Combination Sink	3.4	Pass	N/A	Testing Complete
M45738	In classroom 57	Classroom Combination Drinking Fountain	2.8	Pass	N/A	Testing Complete
M45743	In classroom 12	Classroom Combination Sink	<1	Pass	N/A	Testing Complete
M45744	In classroom 12	Classroom Combination Drinking Fountain	1.3	Pass	N/A	Testing Complete
M45745	In classroom 11	Classroom Combination Sink	<1	Pass	N/A	Testing Complete
M45746	In classroom 11	Classroom Combination Drinking Fountain	6.3	Fail	431	Testing Complete
M45749	In classroom 9	Classroom Combination Sink	<1	Pass	N/A	Testing Complete
M45750	In classroom 9	Classroom Combination Drinking Fountain	<1	Pass	N/A	Testing Complete
M45751	In classroom 8	Classroom Combination Sink	7.0	Fail	7.4	Testing Complete
M45754	In classroom 6	Classroom Combination Sink	1.8	Pass	N/A	Testing Complete
M45755	In classroom 6	Classroom Combination Drinking Fountain	1.4	Pass	N/A	Testing Complete
M45771	In kitchen by cafeteria	Kitchen Sink	13.9	Fail	14.0	Testing Complete
M45772	In kitchen by cafeteria	Kitchen Sink	<1	Pass	N/A	Testing Complete

M45773	In kitchen by cafeteria	Kitchen Sink	<1	Pass	N/A	Testing Complete
M45774	In kitchen by cafeteria	Kitchen Sink	<1	Pass	N/A	Testing Complete
M45784	In work room by admin	Classroom Sink	2.6	Pass	N/A	Testing Complete
M45786	In health room	Nurses Office Sink	2.6	Pass	N/A	Testing Complete



MONTGOMERY COUNTY PUBLIC SCHOOLS DRINKING WATER TESTING 2018

May 25, 2018

Executive Summary:
Burtonsville Elementary School
15516 Old Columbia Pike
Burtonsville, MD 20866

Round of Testing:	Initial
# of Outlets Tested:	75
# of Outlets \geq 20 ppb:	2
Low Value (ppb):	< 1.0
High Value (ppb):	48.6
Follow-Up Testing Required (Samples \geq 20 ppb):	Room 8 (48.6 ppb) Room 8 (23.5 ppb)

Round of Testing:	Follow-Up – 30 sec draw
# of Outlets Tested:	2

Project Status **Testing Complete: Remediation Plan**

Classroom 8– Replace fixture (M45751), in addition to supply line and valve located under sink
Classroom 8– Replace fixture (M45753), in addition to supply line and valve located under sink



May 25, 2018

Mr. Brian Mullikin
Environmental Team Leader
Montgomery County Public Schools
8301 Turkey Thicket Drive
Building A, First Floor
Burtonsville, Maryland 20879

Re: Lead in Water Testing Service

Location: Burtonsville Elementary School
15516 Old Columbia Pike
Burtonsville, MD 20866

Dear Mr. Mullikin:

Professional Services Industries (PSI), Inc. is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of initial lead in water testing at Burtonsville Elementary School, located at 15516 Old Columbia Pike in Burtonsville, MD 20866.

Scope of Services:

PSI conducted lead in water testing at Burtonsville Elementary School in accordance with the Environmental Protection Agency (EPA) and Maryland House Bill (HB) 270. State regulation established an action level of 20 parts per billion (ppb) to evaluate lead levels in school buildings, a concentration EPA recommends that schools take action to reduce lead below this action level. Maryland requires periodic testing for the presence of lead in drinking water in occupied public and nonpublic school buildings. EPA developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

PSI visited the site on 4/4/18 and 4/5/18 to collect samples from 75 drinking water outlets in accordance with current criteria described by the Maryland Department of the Environment (MDE) Draft Lead in Drinking Water—Public and Nonpublic Schools, Title 26, Subtitle 16 Lead, Chapter 07. Two 30 second follow-up samples were collected on 5/8/18.

Samples were submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

Results:

There were two results of the initial lead in water analysis at or above 20 parts per billion (ppb) and subsequent follow up 30 second results are highlighted in the summary table below:



Barcode ID	Sample Location	Date Collected	Initial Sample Result (ppb)	Date Collected	30 Second Follow Up Sample Result (ppb)
M45751	Classroom 8	4/5/18	23.5	5/8/18	<1.0
M45753	Classroom 8	4/5/18	48.6	5/8/18	1.1

The initial lead in water sample results (4/5/18) and 30 second follow up results (5/8/18) are shown in Attachment A.

Discussion:

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children’s brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990’s could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,

PROFESSIONAL SERVICE INDUSTRIES, INC.

Nand Kaushik, P.E.
Department Manager, Environmental Services
Nand.Kaushik@psiusa.com

Attachments: A – Lead in Water Test Summary Table

ATTACHMENT A

Burtonsville ES Water Test Summary Table

Contractor: Professional Services Industries, Inc.

Certified Laboratory: Microbac Laboratories, Inc.

Initial Sample Results for Burtonsville Elementary School (4/5/18)

Barcode ID	Room #	Location	Location Notes	Equipment Type	Results	Pass/Fail	Status
LW01803		Hallway	In Front of Gymnasium	Cooler	<1.0	Pass	Testing Complete
LW01804	24	Classroom		Bubbler - Indoor	1.0	Pass	Testing Complete
LW01805	23	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW01806	20	Classroom		Faucet	1.1	Pass	Testing Complete
LW01807	20	Classroom		Bubbler - Indoor	1.6	Pass	Testing Complete
LW01810		Hallway	Between Room 18 and 19	Cooler	<1.0	Pass	Testing Complete
LW01811	17	Classroom		Faucet	2.7	Pass	Testing Complete
LW01812	17	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW01813		Hallway	Across from Room 58	Cooler	<1.0	Pass	Testing Complete
LW01814	14	Classroom		Faucet	1.3	Pass	Testing Complete
LW01815	14	Classroom		Bubbler - Indoor	1.3	Pass	Testing Complete
LW01816	13	Classroom		Faucet	1.7	Pass	Testing Complete
LW01817	13	Classroom		Bubbler - Indoor	1.3	Pass	Testing Complete
LW01842		Hallway	Across Room 28	Cooler	<1.0	Pass	Testing Complete
LW01843	30	Classroom	Art	Faucet	<1.0	Pass	Testing Complete
LW01844	30	Classroom	Art	Bubbler - Indoor	1.3	Pass	Testing Complete
LW06934	7	Break Room		Faucet	1.8	Pass	Testing Complete
LW06935	4	Classroom		Faucet	2.6	Pass	Testing Complete
LW06936	4	Classroom		Bubbler - Indoor	4.5	Pass	Testing Complete
LW06937	3	Classroom		Faucet	1.5	Pass	Testing Complete
LW06938	3	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
LW06939	2	Classroom		Faucet	1.8	Pass	Testing Complete
LW06940	2	Classroom		Bubbler - Indoor	1.4	Pass	Testing Complete
LW06941	1	Classroom		Faucet	1.6	Pass	Testing Complete
LW06942	1	Classroom		Bubbler - Indoor	1.4	Pass	Testing Complete
LW06943		Hallway	Across from Cafeteria	Cooler	<1.0	Pass	Testing Complete
LW06959		Hallway	Right of Main Entrance	Cooler	<1.0	Pass	Testing Complete
M40119	21	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M40122	21	Classroom		Faucet	1.2	Pass	Testing Complete
M45680	42	Classroom		Faucet	9.4	Pass	Testing Complete

Barcode ID	Room #	Location	Location Notes	Equipment Type	Results	Pass/Fail	Status
M45681	42	Classroom		Bubbler - Indoor	3.4	Pass	Testing Complete
M45684	28	Classroom		Faucet	1.4	Pass	Testing Complete
M45685	28	Classroom		Bubbler - Indoor	1.8	Pass	Testing Complete
M45691	33	Classroom		Faucet	3.2	Pass	Testing Complete
M45692	33	Classroom		Bubbler - Indoor	2.3	Pass	Testing Complete
M45693	34	Classroom		Faucet	1.2	Pass	Testing Complete
M45694	34	Classroom		Bubbler - Indoor	2.2	Pass	Testing Complete
M45702	27	Classroom		Faucet	<1.0	Pass	Testing Complete
M45703	27	Classroom		Bubbler - Indoor	1.6	Pass	Testing Complete
M45704	26	Classroom		Faucet	1.7	Pass	Testing Complete
M45705	26	Classroom		Bubbler - Indoor	2.1	Pass	Testing Complete
M45706	24	Classroom		Faucet	1.6	Pass	Testing Complete
M45708	25	Classroom		Faucet	1.6	Pass	Testing Complete
M45709	25	Classroom		Bubbler - Indoor	1.6	Pass	Testing Complete
M45710	23	Classroom		Faucet	2.1	Pass	Testing Complete
M45712	22	Classroom		Faucet	1.5	Pass	Testing Complete
M45713	22	Classroom		Bubbler - Indoor	1.0	Pass	Testing Complete
M45716	19	Classroom		Faucet	1.5	Pass	Testing Complete
M45717	19	Classroom		Bubbler - Indoor	1.0	Pass	Testing Complete
M45723	18	Classroom		Faucet	2.1	Pass	Testing Complete
M45724	18	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M45732	58	Classroom		Faucet	1.7	Pass	Testing Complete
M45733	58	Classroom		Bubbler - Indoor	1.6	Pass	Testing Complete
M45735	55	Classroom		Faucet	2.2	Pass	Testing Complete
M45736	55	Classroom		Bubbler - Indoor	1.1	Pass	Testing Complete
M45737	57	Classroom		Faucet	2.3	Pass	Testing Complete
M45738	57	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M45743	12	Classroom		Faucet	1.4	Pass	Testing Complete
M45744	12	Classroom		Bubbler - Indoor	1.1	Pass	Testing Complete
M45745	11	Classroom		Faucet	1.4	Pass	Testing Complete
M45746	11	Classroom		Bubbler - Indoor	1.5	Pass	Testing Complete
M45747	10	Classroom		Faucet	7.1	Pass	Testing Complete
M45748	10	Classroom		Bubbler - Indoor	3.2	Pass	Testing Complete
M45749	9	Classroom		Faucet	3.4	Pass	Testing Complete
M45750	9	Classroom		Bubbler - Indoor	1.5	Pass	Testing Complete
M45751	8	Classroom		Faucet	23.5	Fail	Follow-Up Testing Needed
M45753	8	Classroom		Bubbler - Indoor	48.6	Fail	Follow-Up Testing Needed
M45754	6	Classroom		Faucet	3.1	Pass	Testing Complete
M45755	6	Classroom		Bubbler - Indoor	2.3	Pass	Testing Complete

Barcode ID	Room #	Location	Location Notes	Equipment Type	Results	Pass/Fail	Status
M45771		Kitchen Cafeteria		Faucet	<1.0	Pass	Testing Complete
M45772		Kitchen Cafeteria		Faucet	<1.0	Pass	Testing Complete
M45773		Kitchen Cafeteria		Faucet	<1.0	Pass	Testing Complete
M45774		Kitchen Cafeteria		Faucet	<1.0	Pass	Testing Complete
M45784		Work Room Admin		Faucet	1.8	Pass	Testing Complete
M45786		Health Room		Faucet	1.5	Pass	Testing Complete
M45788		Work Room Media Center		Faucet	6.0	Pass	Testing Complete

*ppb = parts per billion

Contractor: Professional Services Industries, Inc.
Certified Laboratory: Microbac Laboratories, Inc.

Follow Up Sample Results for Burtonsville Elementary School (5/8/18)

Barcode ID	Room Number	Location	Equipment Type	Initial draw (2 nd) (PPB)	30 Second Draw (PPB)	Status
M45751	8	Classroom	Faucet	6.4	<1.0	Remediation required – replace fixture, in addition to supply line and valve located under sink
M45753	8	Classroom	Bubbler - Indoor	5.8	1.1	Remediation required – replace fixture, in addition to supply line and valve located under sink

*ppb = parts per billion

Note: Fixture(s) with elevated test results were immediately removed from service. Subsequent 2nd round testing was performed on these fixture(s) for further diagnostics for remediation. Because the fixture was shut off after the first test, the subsequent test results may not be representative of an in-use fixture because of stagnant water in the supply line and the operation of shut off valves prior to the tests. All fixtures with elevated test results are to be remediated. After remediation, post remediation testing will be conducted before the fixture is returned to service.