

Montgomery County Public Schools Lead in Drinking Water Testing Report

**Cresthaven Elementary School
1234 Cresthaven Dr.
Silver Spring, MD 20903**

Report Date: May 16th, 2024

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the State Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by Inspection Experts Inc. is presented in the table below.

Sampling Date	4/3/2024
# of Outlets Tested	46
# of Outlets \geq 5 ppb	0

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be shut-down within 24 hours, a follow-up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass outlets, food, cosmetics, exposure in the work place and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s) A – Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for Cresthaven ES

Outlet Barcode	Outlet Location	Outlet Type	Initial Results (ppb)	Pass/Fail	Status
LW06096	In hallway adjacent to main office	Drinking Water Fountain - Cooler/Chiller Style	<2.0	Pass	Testing Complete
LW06125	In hallway adjacent to 15	Drinking Water Fountain - Cooler/Chiller Style	<2.0	Pass	Testing Complete
LW06127	In hallway adjacent to main office	Drinking Water Fountain - Cooler/Chiller Style	<2.0	Pass	Testing Complete
M08725	In classroom 31	Drinking Water fountain - Bubblers Style	<2.0	Pass	Testing Complete
M08727	In classroom 1	Drinking Water fountain - Bubblers Style	<2.0	Pass	Testing Complete
M08730	In classroom 5	Drinking Water fountain - Bubblers Style	<2.0	Pass	Testing Complete
M08731	In classroom 7	Drinking Water fountain - Bubblers Style	<2.0	Pass	Testing Complete
M08734	In classroom 11	Drinking Water fountain - Bubblers Style	<2.0	Pass	Testing Complete
M08735	In classroom 13	Drinking Water fountain - Bubblers Style	<2.0	Pass	Testing Complete
M08737	In hallway adjacent to 13	Drinking Water Fountain - Cooler/Chiller Style	<2.0	Pass	Testing Complete
M08741	Hallway adjacent room 15	Drinking Water fountain - Bubblers Style	<2.0	Pass	Testing Complete

Outlet Barcode	Outlet Location	Outlet Type	Initial Results (ppb)	Pass/Fail	Status
M08742	In classroom 17	Drinking Water fountain - Bubblers Style	<2.0	Pass	Testing Complete
M08743	In classroom 19	Drinking Water fountain - Bubblers Style	<2.0	Pass	Testing Complete
M08750	In classroom 23	Drinking Water fountain - Bubblers Style	<2.0	Pass	Testing Complete
M08751	In kitchen	Faucet, Cold	<2.0	Pass	Testing Complete
M08752	In kitchen	Faucet, Cold	<2.0	Pass	Testing Complete
M08753	In kitchen	Faucet, Cold	<2.0	Pass	Testing Complete
M08754	In kitchen	Faucet, Cold	<2.0	Pass	Testing Complete
M08757	In instructional music room 137	Drinking Water fountain - Bubblers Style	3.7	Pass	Testing Complete
M08766	In health room	Faucet, Cold	<2.0	Pass	Testing Complete
M08769	In health room	Faucet, Cold	<2.0	Pass	Testing Complete
M08774	In music classroom 101	Drinking Water fountain - Bubblers Style	<2.0	Pass	Testing Complete
M08776	In classroom 111	Drinking Water fountain - Bubblers Style	<2.0	Pass	Testing Complete

Outlet Barcode	Outlet Location	Outlet Type	Initial Results (ppb)	Pass/Fail	Status
M08782	In hallway adjacent to gym	Drinking Water Fountain - Cooler/Chiller Style	<2.0	Pass	Testing Complete
M08783	In hallway adjacent to gym	Drinking Water Fountain - Cooler/Chiller Style	<2.0	Pass	Testing Complete
M08792	In ESOL 123	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
M08795	In resource center 257	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
M08796	In hallway adjacent to 250	Drinking Water Fountain - Cooler/Chiller Style	<2.0	Pass	Testing Complete
M08797	In hallway adjacent to 250	Drinking Water Fountain - Cooler/Chiller Style	<2.0	Pass	Testing Complete
M08799	In classroom 250	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
M08801	In classroom 248	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
M08808	In classroom 242	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
M08811	In classroom 240	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
M08813	In classroom 202	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
M08814	In classroom 206	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete

Outlet Barcode	Outlet Location	Outlet Type	Initial Results (ppb)	Pass/Fail	Status
M08817	In classroom 203	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
M08818	In classroom 207	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
M08820	In classroom 213	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
M08826	In classroom 219	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
M08828	In classroom 222	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
M08831	In hallway adjacent to 224	Drinking Water Fountain - Cooler/Chiller Style	<2.0	Pass	Testing Complete
M08832	In classroom 224	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
M08834	In classroom 225	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete
LW11780	Hallway adjacent to Gym	Bottle Refill Dispenser/Water Refill Station	<2.0	Pass	Testing Complete
LW11782	Hallway adjacent to Main office	Bottle Refill Dispenser/Water Refill Station	<2.0	Pass	Testing Complete
M08840	In classroom 241	Drinking Water fountain - Bubbler Style	<2.0	Pass	Testing Complete

Montgomery County Public Schools Lead in Drinking Water Testing Report

**Cresthaven Elementary School
1234 Cresthaven Drive
Silver Spring, MD 20903**

Report Date: March 22nd, 2022

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the Montgomery County Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by SaLUT are presented in the table below.

Sampling Date	11/04/2021
# of Outlets Tested	76
# of Outlets \geq 5 ppb	1

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be immediately shut-down, a follow-up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, cosmetics, exposure in the work place and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s) A – Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for Cresthaven ES

Fixture Barcode	Fixture Location	Fixture Type	Initial Results (ppb)	Pass/Fail	Follow up Results (ppb)	Status
LW06096	In hallway adjacent to main office	Drinking Fountain	<1.0	Pass	N/A	Testing Complete
LW06125	In hallway adjacent to 15	Drinking Fountain	<1.0	Pass	N/A	Testing Complete
LW06126	In health room office 102A	Nurses Office Sink	8.3	Fail	<1	Testing Complete
LW06127	In hallway adjacent to main office	Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08725	In classroom 31	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08726	In classroom 31	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08727	In classroom 1	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08728	In classroom 1	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08729	In classroom 5	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08730	In classroom 5	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08731	In classroom 7	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08732	In classroom 7	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08733	In classroom 11	Classroom Combination Sink	2.9	Pass	N/A	Testing Complete
M08734	In classroom 11	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08735	In classroom 13	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08736	In classroom 13	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08737	In hallway adjacent to 13	Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08741	In classroom 17	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08742	In classroom 17	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08743	In classroom 19	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08744	In classroom 19	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08749	In classroom 23	Classroom Combination Sink	2.7	Pass	N/A	Testing Complete
M08750	In classroom 23	Classroom Combination Drinking Fountain	2.1	Pass	N/A	Testing Complete
M08751	In kitchen	Kitchen Sink	<1.0	Pass	N/A	Testing Complete
M08752	In kitchen	Kitchen Sink	<1.0	Pass	N/A	Testing Complete
M08753	In kitchen	Kitchen Sink	<1.0	Pass	N/A	Testing Complete
M08754	In kitchen	Kitchen Sink	1.7	Pass	N/A	Testing Complete
M08757	In instructional music room 137	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08758	In instructional music classroom 137	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08766	In health room	Nurses Office Sink	<1.0	Pass	N/A	Testing Complete

M08769	In health room	Nurses Office Sink	<1.0	Pass	N/A	Testing Complete
M08771	In administration work room 100C	Classroom Sink	<1.0	Pass	N/A	Testing Complete
M08773	In music classroom 101	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08774	In music classroom 101	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08775	In media center office 103A	Classroom Sink	<1.0	Pass	N/A	Testing Complete
M08776	In classroom 111	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08777	In classroom 111	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08782	In hallway adjacent to gym	Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08783	In hallway adjacent to gym	Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08789	In break room 114	Classroom Sink	<1.0	Pass	N/A	Testing Complete
M08792	In ESOL 123	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08793	In ESOL 123	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08794	In resource center 257	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08795	In resource center 257	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08796	In hallway adjacent to 250	Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08797	In hallway adjacent to 250	Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08798	In classroom 250	Classroom Combination Sink	1.6	Pass	N/A	Testing Complete
M08799	In classroom 250	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08800	In classroom 248	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08801	In classroom 248	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08808	In classroom 242	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08809	In classroom 242	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08810	In classroom 240	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08811	In classroom 240	Classroom Combination Drinking Fountain	2.6	Pass	N/A	Testing Complete
M08812	In classroom 202	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08813	In classroom 202	Classroom Combination Drinking Fountain	4.7	Pass	N/A	Testing Complete
M08814	In classroom 206	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08815	In classroom 206	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08816	In classroom 203	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08817	In classroom 203	Classroom Combination Drinking Fountain	1.3	Pass	N/A	Testing Complete
M08818	In classroom 207	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08819	In classroom 207	Classroom Combination Sink	1.6	Pass	N/A	Testing Complete
M08820	In classroom 213	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete

M08821	In classroom 213	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08826	In classroom 219	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08827	In classroom 219	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08828	In classroom 222	Classroom Combination Drinking Fountain	1.2	Pass	N/A	Testing Complete
M08829	In classroom 222	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08830	In hallway adjacent to 224	Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08831	In hallway adjacent to 224	Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08832	In classroom 224	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08833	In classroom 224	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08834	In classroom 225	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete
M08835	In classroom 225	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08839	In classroom 241	Classroom Combination Sink	<1.0	Pass	N/A	Testing Complete
M08840	In classroom 241	Classroom Combination Drinking Fountain	<1.0	Pass	N/A	Testing Complete



Montgomery County Public Schools Lead in Drinking Water Testing 2018

May 24, 2018

Executive Summary:
Cresthaven Elementary School
1234 Cresthaven Drive
Silver Spring, Maryland 20903

Round of Testing:	Initial
# of Outlets Tested:	75
# of Outlets \geq 20 ppb:	0
Low Value (ppb):	<1.0
High Value (ppb):	4.0

Project Status:
Testing Complete: All results less than 20 ppb.



May 24, 2018

Mr. Brian Mullikin, MS
Environmental Team Leader
Montgomery County Public Schools
Division of Maintenance
Gaithersburg, Maryland 20879

Re: Drinking Water Testing

KCI Job #1214634193

Location: Cresthaven Elementary School

1234 Cresthaven Drive
Silver Spring, Maryland 20903

Dear Mr. Mullikin:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of Initial lead in water testing at Cresthaven Elementary School, located at 1234 Cresthaven Drive in Silver Spring, Maryland 20903.

SCOPE OF SERVICES

KCI conducted lead in water testing at Cresthaven Elementary School in accordance with the Environmental Protection Agency (EPA) and Maryland House Bill (HB) 270. State regulation established an action level of 20 parts per billion (ppb) to evaluate lead levels in school buildings, a concentration EPA recommends that schools take action to reduce lead below this action level. Maryland requires periodic testing for the presence of lead in drinking water in occupied public and nonpublic school buildings. EPA developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

KCI visited the site on 4/17/2018 and 4/18/2017 to collect samples from 75 drinking water outlets in accordance with current criteria described by the Maryland Department of the Environment (MDE) Draft Lead in Drinking Water - Public and Nonpublic Schools, Title 26, Subtitle 16 Lead, Chapter 07.

Samples were submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

RESULTS

There are no results of the lead in water analysis at or above 20 parts per billion (ppb). The lead in water sample results for sample collection date 4/18/2017 are shown in Attachment A.

DISCUSSION

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children's brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990's could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,
KCI Technologies, Inc.



Kamau McAbee
MDE Certified Water Sampler #8281KM

Attachment:

A- Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

Contractor: KCI Technologies, Inc.

Certified Laboratory: Microbac Laboratories, Inc.

Sample Results for Cresthaven Elementary School

Barcode ID	Room #	Location	Location Notes	Equipment Type	Results (PPB)*	Pass/Fail	Status
LW06096		Hallway	Outside Of Apr	Cooler	<1.0	Pass	Testing Complete
LW06125		Hallway	Across From Cr 13	Cooler	<1.0	Pass	Testing Complete
LW06126	102A	Office Health Room		Faucet	4.0	Pass	Testing Complete
LW06127		Hallway	Outside Of Apr	Cooler	<1.0	Pass	Testing Complete
M08725	31	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08726	31	Classroom		Faucet	<1.0	Pass	Testing Complete
M08727	1	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08728	1	Classroom		Faucet	<1.0	Pass	Testing Complete
M08729	5	Classroom		Faucet	<1.0	Pass	Testing Complete
M08730	5	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08731	7	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08732	7	Classroom		Faucet	<1.0	Pass	Testing Complete
M08733	11	Classroom		Faucet	<1.0	Pass	Testing Complete
M08734	11	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08735	13	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08736	13	Classroom		Faucet	<1.0	Pass	Testing Complete
M08737		Hallway	Across from CR 13	Cooler	<1.0	Pass	Testing Complete
M08741	17	Classroom		Faucet	<1.0	Pass	Testing Complete
M08742	17	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08744	19	Classroom		Faucet	<1.0	Pass	Testing Complete
M08749	23	Classroom		Faucet	<1.0	Pass	Testing Complete
M08750	23	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08751		Kitchen		Faucet	<1.0	Pass	Testing Complete

Barcode ID	Room #	Location	Location Notes	Equipment Type	Results (PPB)*	Pass/Fail	Status
M08752		Kitchen		Faucet	<1.0	Pass	Testing Complete
M08753		Kitchen		Faucet	<1.0	Pass	Testing Complete
M08754		Kitchen		Faucet	<1.0	Pass	Testing Complete
M08757	137	Inst Music		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08758	137	Inst Music		Faucet	<1.0	Pass	Testing Complete
M08766	102	Health		Faucet	<1.0	Pass	Testing Complete
M08769		Office Health Room		Faucet	<1.0	Pass	Testing Complete
M08771	100C	Work Room Admin	inside Admin	Faucet	<1.0	Pass	Testing Complete
M08773	101	Music		Faucet	<1.0	Pass	Testing Complete
M08774	101	Music		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08775	103A	Office Media Center	Inside Imc	Faucet	<1.0	Pass	Testing Complete
M08776	111	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08777	111	Classroom		Faucet	<1.0	Pass	Testing Complete
M08782		Hallway	Outside Of Gym	Cooler	<1.0	Pass	Testing Complete
M08783		Hallway	Outside Of Gym	Cooler	<1.0	Pass	Testing Complete
M08789	114	Break Room		Faucet	<1.0	Pass	Testing Complete
M08792	123	ESOL		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08793	123	ESOL		Faucet	<1.0	Pass	Testing Complete
M08794	257	Resource		Faucet	<1.0	Pass	Testing Complete
M08795	257	Resource Center		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08796		Hallway	Across from CR 250	Cooler	<1.0	Pass	Testing Complete
M08797		Hallway	Across from CR 250	Cooler	<1.0	Pass	Testing Complete
M08798	250	Classroom		Faucet	<1.0	Pass	Testing Complete
M08799	250	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08800	248	Classroom		Faucet	<1.0	Pass	Testing Complete
M08801	248	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08808	242	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete

Barcode ID	Room #	Location	Location Notes	Equipment Type	Results (PPB)*	Pass/Fail	Status
M08809	242	Classroom		Faucet	<1.0	Pass	Testing Complete
M08810	240	Classroom		Faucet	<1.0	Pass	Testing Complete
M08811	240	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08812	202	Classroom		Faucet	<1.0	Pass	Testing Complete
M08813	202	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08814	206	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08815	206	Classroom		Faucet	<1.0	Pass	Testing Complete
M08816	203	Classroom		Faucet	<1.0	Pass	Testing Complete
M08817	203	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08818	207	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08819	207	Classroom		Faucet	<1.0	Pass	Testing Complete
M08820	213	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08821	213	Classroom		Faucet	<1.0	Pass	Testing Complete
M08826	219	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08827	219	Classroom		Faucet	<1.0	Pass	Testing Complete
M08828	222	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08829	222	Classroom		Faucet	<1.0	Pass	Testing Complete
M08830		Hallway	Next to CR 224	Cooler	<1.0	Pass	Testing Complete
M08831		Hallway	Next to CR 224	Cooler	<1.0	Pass	Testing Complete
M08832	224	Classroom		Bubbler - Indoor	3.6	Pass	Testing Complete
M08833	224	Classroom		Faucet	<1.0	Pass	Testing Complete
M08834	225	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete
M08835	225	Classroom		Faucet	<1.0	Pass	Testing Complete
M08839	241	Classroom		Faucet	<1.0	Pass	Testing Complete
M08840	241	Classroom		Bubbler - Indoor	<1.0	Pass	Testing Complete

*PPB = parts per billion